

THERMODYNAMIC ASSESSMENT OF EXISTING GAS TURBINES WITH INLET EVAORATIVE AND OVERSPRAY FOGGING

Gunjan Bansal

Research Scholar, Calorx Teachers' University, Ahmedabad, Gujarat

1. INTRODUCTION

Compressor intake air cooling is developing to be an important area of research in the Modern Gas Turbine Power Plants. The state of art literature survey of this area is briefly described below.

2. REVIEW LITERATURE

The present literature can be classified into the following categories:

- a) Evaporative Cooling
- b) Refrigeration Cooling
- c) Hybrid System cooling

The literature review of these systems is described below:

Evaporative Cooling

Kumar and Krishna (1), investigated the improved gas turbine efficiency using spray coolers and through Alternative Regeneration Configuration. Cooling of air at compressor inlet helps in increasing the density of air flowing through the plant while alternative regeneration causes the air to enter the combustion chamber at a higher temperature. The plant performance characteristics were examined for a set of design and operational parameters including ambient temperature, relative humidity, turbine inlet temperature and pressure ratio. At design point for reference plant (simple cycle), the efficiency was 34% whereas by using alternative regeneration and spray cooler, it increased to 47%.

Bejan et al (2), gave the method of exergy analysis of the thermal systems. The physical and chemical exergy of various common substances was given. Al-Amiri and Zamzam (3), assessed the benefits of incorporating combustion turbine inlet air cooling systems into a reference combustion turbine plant, which was based on a simple cycle under base load mode. The main performance characteristics of both evaporative and refrigerative cooling systems were explored by examining he effect of several parameters including inlet air temperature, air flow-to-turbine output ratio, coefficient of performance and degree of hours. The impact of these parameters was presented

against annual gross energy increase, average heat rate reduction, cooling load requirements and net power increase. Finally, a feasibility design chart was constructed to outline the economic returns of employing a refrigerative cooling unit against prescribed inlet air temperature values using a wide range of combustion turbine mass flow rates.

Alhazmy and Najjar (4), studied the performance enhancement of gas turbine power plants using spray cooling (water spraying system and cooling coil), Spray cooler reduces the temperature of incoming air 3-15 C enhancing the power by 1-7% and improving efficiency by 3%. Lucia et al (5), presented a comparative analysis of different solutions for cooling compressor inlet air for LM 60-0 gas turbine in a cogeneration plant operated in base load. Reference was made to two sites in northern and southern Italy whose climatic data series for modeling the variations in ambient temperature during the single day were used to account for the effects of climate in the simulation. The results confirmed evaporative cooling to be cost effective while absorption systems have a higher cost but are more versatile and powerful in base-load operation.

Bhargava and Meher-Homji (6), did a parametric analysis on the effects of inlet fogging and evaporative conditions on a wide range of existing gas turbines. Arora (7), presented a basic as well as applied thermodynamic treatment of refrigeration and air conditioning in a very comprehensive manner. A sound physical basis had been laid for obtaining fairly precise estimates of refrigeration and air-conditioning equipment.

Moran (8), presented an effective and systematic method that uses both the first and second laws of thermodynamics for the performance analysis and design of energy systems known as availability analysis. It included the use of availability equation as an important unifying concept, a thorough discussion of meaning and use of second law efficiencies, exact and appropriate methods for availability calculation and use in field of engineering economics.

Cammarata et al (9), investigated an application of exergetic theory to an air-conditioning system for optimization purposes. The thermodynamic model was stated according to recent formulations of exergy for moist air streams, while the economic model was based on cost balance equations and real cost data for mechanical equipment. The optimum configuration was obtained through an iterative procedure aimed at the design improvement.

Refrigeration cooling

This system includes vapour compression and vapour absorption systems which are in use for a long time in industries.

Haselden and Chen (10), developed and tested a steady state design simulation program for air conditioning systems using binary refrigerant mixtures. The pinch method was introduced to facilitate the refrigerant cycle simulation. Horuz and Caliander (11), did an experimental investigation of performance of a commercially available Vapour Absorption System. The response of system to variations in chilled water inlet temperature, chilled water level in evaporator drum, chilled water flow rate and variable heat input were presented. Waked (12) carried out the Second Law Analysis for a Cogeneration Power-Absorption Cooling Plant. A typical reference steam

power plant was used to show the efficient use of fuel in producing both power and process heat to operate absorption cooling units for air-conditioning purposes.

2.2.3 Hybrid system cooling

The hybrid system demonstrated a higher gain in power output and efficiency than evaporative cooling for a simple gas turbine, independent of ambient air temperature.

3. CONCLUSIONS

By the study of present literature following conclusions can be drawn:

- A) Evaporative cooling system is the cheapest cooling system in use today.
- B) Gain in output is approximately 5% by the use of evaporative cooling system.
- C) Vapour compression and vapour absorption system produce more degree of cooling than evaporative cooling system.
- D) Vapour compression and vapour absorption system are more expensive than evaporative cooling system.
- E) Performance of the selected system is largely affected by the local weather patterns.
- F) Hybrid systems offer a greater degree of cooling and therefore power output and efficiency of the gas turbine plant is higher.

4. SCOPE OF THE WORK

From the literature survey of work done by different people on the compressor intake air-cooling, it is very clear that lot of scope is lying in analyzing the methods of air-cooling. Evaporative cooling and absorption chiller system are the good choice for economical and efficiency purpose. In the present work , energy and second law analysis of water/LiBr vapour absorption refrigeration system has been investigated by the exergy method.

REFERENCES

1. RAVI KUMAR N , Dr. RAMA KRISHNA K , Dr. SITA RAMA RAJU A V , “IMPROVED GAS TURBINE EFFICIENCY USING SPRAY COOLERS AND THROUGH ALTERNATIVE REGENERATOR CONFIGURATION” ISHMT-ASME , Heat and Mass transfer conference , jan 2006 , pp -1819-1824
2. VELASCO GOMEZ E., REY MARTINEZ F J , VARELA DIEZ F , MOLINA LEVYA M J , HERRERO MARTIN R , “ DESCRIPTION AND EXPERIMENTAL RESULTS OF A SEMI INDIRECT CERAMIC EVAPORATIVE COOLER” INTERNATIONAL JOURNAL OF REFRIGERATION VOL.28 MARCH 2005 PP- 654 -662
3. DATTA S ,SAHGAL PN, DHINGRA SC , KISHORE V.V V N , “DESIGN AND EVAPORATIVE CHARACTERISTICS OF EVAPORATIVE COOLING SYSTEMS “ INTERNATIONAL JOURNAL OF REFRIGERATION VOL 10 JULY1987 PP-205-208

4. ADRIAN BEJAN , GEORGE TSATSARONIS , MICHAEL MORAN M “ THERMAL DESIGN AND OPTIMIZATION” JOHN WILEY AND SONS (1996) PP 159-169
5. DAWQOUD B , ZURIGAT Y H , BORTMANY J “THERMODYNAMIC ASSESS MENT OF POWER REQUIREMENTAND IMPACT OF DIFFEERENT GAS TURBINE INLET AIR COOLING TECHNIQUES AT TWO DIFFERENT LOCATIONS IN OMAN” APPLIED THERMAL ENGINEERING VOL 25 (2005)PP-1579 -1598
6. DAWQOUD B , ZURIGAT Y H , BORTMANY J “THERMODYNAMIC ASSESS MENT OF POWER REQUIREMENTAND IMPACT OF DIFFEERENT GAS TURBINE INLET AIR COOLING TECHNIQUES AT TWO DIFFERENT LOCATIONS IN OMAN” APPLIED THERMAL ENGINEERING VOL 25 (2005)PP-1579 -1598
7. ALHAZMY M M , NAJJAR Y S H , “AUGMENTATION OF GAS TURBINE PERFORMANCE USING AIR COOLERS , APPLIED THERMAL ENGINEERING VOL 24 2004 PP- 415-429
8. DE LUCIA M., LANFRANCHI C., BOGGIO V., “BENEFITS OF COMPRESSOR INLET AIR COOLING FOR GAS TURBINE COGENERATION PLANTS’, JOURNAL OF ENGINEERING FOR GAS TURBINE AND POWER, VOL. 118 (JULY 19660, PP 598-602.
9. BHARGAVA R., MEHER-HOMJI C.B. “PARAMETRICANALYSIS OF EXISTING GAS TURBINES WITH INLET EVAORATIVE AND OVERSPRAY FOGGING”,JOURNAL OF ENGINEERING FOR GAS TURNBINES AND POWER, VOL. 127, (JAN 2005), PP 145-158.
10. ARORA C.P. “REGRIGERATION AND AIR CONDITIONING”, TATA MCGRAW-HILL PUBLISHING COMPANY LIMITED, 1983 PP 53-104, 304-325, 337-406.
11. MORAN M.J., “AVAILABILITY ANALYSIS”, ASME RESS, NEW YORK, NY, (1989), PP. 123-143.
12. CAMMARATA G. FICHERA A., MAMMINO L., MARLETTA L., “EXERGONOMIC OPTIMIZATION OF AN AIR-CONDITIONING SYSTEM”, JOURNAL OF ENERGY RESOURCES TECHNOLOGY, VOL. 119, (MAR 1997), PP62-69.
13. AIT-ALI M.A. “OPTIMUM POWER B OOSTING OF GAS TURBINE CYCLES WITH COMPRESSOR INLET AIR REFRIGERATION “, JOURNAL OF ENGINEERING FOR GAS TURBINES AND POWER, VOL. 119, (JAN 1997), PP124-133.
14. NIKOLAIDIS C., PROBERT D., “EXERGY-METHOD ANALYSIS OF A TWO-STAGE VAPOUR COMPRESSION REFRIGERATION-PLANT’S PERFORMANCE”, APPLIED ENERGY, VOL.60, (1998), PP 241-256.

15. HASELDEN GEOFFREY G., "A COMPUTER SIMULATION PROGRAM FOR MIXED-REGRIGERANT AIR-CONDITIONING", INTERNATIONAL JOURNAL OF REGRIGERATION, VOL.17 NUMBER 5, (1994),PP343-350.
16. YUNHO HWANG, "POTENTIAL ENERGY BENEFITS OF INTEGRATED REFRIGERATION SYSTEM WITH MICROTURBINE AND ABSORPTION CHILLER",INTERNATIONAL JOURNAL OF REGRIGERATION, VOL.27, (2004), PP816-829.
17. HORUZI., CALLANDER T.M.S., "EXPERIMENTAL INVESTIGATION OF A VAPOUR ABSORPTION REGRIGEERATION SYSTEM", INTERNATIONAL JOURNAL OF REGRIGERATION, VOL.27,(2004)PP10-16.
18. WAKED A.M., "SECOND LAW ANALYSIS OF A COGENERATION POWER-ABSORPTION COOLING PLANT", HEAT RECOVERY SYSTEMS &CHP, VOL.11(1991),PP113-120.
19. ASDRUBALI F., GRIGNAFFINI S., "EXPERIMENTAL EVALUATION OF THE PERFORMANCES OF A H2O-LIBR ABSORPTION REGRIGERAATOR UNDER DIFFERENT SERVICE CONDITIONS", INTERNATIONAL JOURNAL OF REGRIGERATION, VOL.28,(2005),PP489-497.
20. GERSHON GROSSMAN, ABDI ZALTASH, "ABSIM-MODULAR SIMULATION OF ADVANCED ABSORPTION SYSTEMS", INTERANTIONAL JORNAL OF REFRIGERATION, VOL.24(2001),PP531-543.
21. WAKED A.M., "SECOND LAW ANALYSIS OF A COGENERATION POWER-ABSORPTION COOLING PLANT", HEAT RECOVERY SYSTEMS &CHP, VOL.11(1991),PP113-120.
22. ANTONIO DE LUCAS , MARIANA DO , JOSE ANT,"PERFORMANCE EVALUATION AND SIMULATION FO A NEW ABSORBENT FOR AN ABSORPTION REFRIGERATION SYSTEM " INTERNATIONAL JOURNAL OF REFRIGERATION , VOL 27 2004 PP 324-330
23. KAITA Y , " THERMODYNAMIC PROPERTIES OF LiBr –water SOLUTION AT HIGH TEMPERATURES " IINTERNATIONAL JOURNAL OF REFRIGERATION VOL24 2001 PP-374 390
24. MISRA R D SAHOO PK, GUPTA A , MARIANA DO , JOSE ANT,"PERFORMANCE EVALUATION AND SIMULATION FO A NEW ABSORBENT FOR AN ABSORPTION REFRIGERATION SYSTEM " IRANSFER ENGNTERNATIONAL JOURNAL OF REFRIGERATION , VOL 27 2004 PP 324-330
25. AHMADUL AMEEN "REFRIGERATION AND AIR CONDITIONING" PRENTICE HALL OF INDIA PVT LNE BASED PTD 2006 PP 79 93

26. POPIEL CO AND WOJTKOWIAK J , “SIMPLE FORMULAS FOR THERMOPHYSICAL PROPERTIES OF LIQUID WATER FOR REFRIGERATION CALCULATIONS HEAT TRANSFER ENGG. VOL 19 1998 PP87-101
27. KAKARAS E, DOUKELIS A , PRELIPCEANU A , KARELLAS S , “INLET AIR COOLING METHODS FOR GAS TURBUINE BASED POWER PLANTS “ JOURNAL OF ENGINEERING FOR GAS TURBINE POWER VOL128 APRIL 2006 PP 312-327
28. CRAIG CORTES , P E AND DANIEL WILLAMS , P E, “ GAS TURBINE INLET AIR COOLING TECHNIQUES AN OVERVIEW OF CURRENT TECHNOLOGIES” SIEMENS WSTING HOUSE POWERGEN NEVADA SEPT 2003
29. TALBI MM , AGNEW B M M “ EXERGY ANALYSIS AN ABSORPTION REFRIGERATION USING LITHIUM BROMIDE AND WATER AS THE WORKING FLUIDS “ APPLIED THERMAKL ENGINEERING VOL 20 2000 PP – 619-630
30. ONDER KIZILKAN ARZU SENCAN KALOGIROU SOTERIS A , “ THERMOECONOMIC OPTIMIZATION OF A LIBR ASORPTION REFRIGERATION SYSTEM “ CHEMICAL ENGG AND PROCESSING VOL XXX 2006 PP1-9.
31. FLORIDES G A , KALOGIROU SA , TASSOU SA , WROBEL L C , “ MODELLING SIMULATION AND WARMING IMPACT ASSESSMENT OF A DOMESTIC SIZE ABSORPTION SOLAR COOKING SYSTEM “ APPLIED THERMAL ENGINEERING vol 22 2002 Pp - 1313-1325.
32. joudi Khalid A LAFTA ALI H “ SIMULATION FO A SIMPLE VAPOR ABSORPTION REFRIGERATION SYSTEM “ ENERGY CONVERSION AND MANAGEMENT VOL 42 2001 PP 1575- 1605
33. MISRA R D SAHOO P K GUPTA A , THERMOECONOMIC EVALUATION AND OPTIMIZATION OF A DOUBLE EFFECT REFRIGERATION SYSTEM “ INTERNATIONS JOURNAL OF REFRIGERATION VOL 28 2005 PP-331-343
34. XU SM , ZHANG L LAING J DU R “ NUMERICAL SIMULATION OF AN ADVANCED ENERGY STORAGE SYSTEM USING WATER LI BR AS WORKING FLUID PART 1 SYSTEM DESIGN VOL 30 PP 354-363
35. . XU SM , ZHANG L LAING J DU R “ NUMERICAL SIMULATION OF AN ADVANCED ENERGY STORAGE SYSTEM USING WATER LI BR AS WORKING FLUID PART2 SYSTEM DESIGN VOL 30 PP 354-363
36. TOZER ROERT M JAMES PON W , FUNDAMENTAL THERMODYNAMICS OF IDEAL ABSORPTION CYCLES “ INTERNATIONAL JOURNAL OF REFRIGERATION VOL 20 1997 PP 120 135

37. ROBERT TOZER , ATHAR SYED , GRAEME MAIDMENT, EXTENDED TEMPERATURE ENTROPY T S DIAGRAMS FOR AQUEOUS Li Br ABSORPTION REFRIGERATION SYSTEM INTERNATIONAL JOURNAL OF REFRIGERATION VOL 28 2005 PP -689 -697